

1. PRINT ONLY IN SPACES PROVIDED
2. CHECK CORRECT BOX WHERE APPLICABLE

QUARTY OR DISTRICT: Frontenac TOWNSHIP, BOROUGH, CITY, TOWN, VILLAGE: Leedsborough CON. BLOCK, TRACT, SURVEY, ETC.: 6 LOT: Part 17
OWNER (SURNAME FIRST): Loes Rick ADDRESS: RR#2 Perth Road, Ontario, K6H-2L0 DATE COMPLETED: DAY 30 MO 7 YR 90

LOG OF OVERBURDEN AND BEDROCK MATERIALS (SEE INSTRUCTIONS)

GENERAL COLOUR	MOST COMMON MATERIAL	OTHER MATERIALS	GENERAL DESCRIPTION	DEPTH - FEET	
				FROM	TO
Brown	Sand			0	2
Green	Granite			2	46
Black	Granite			46	63
Red Grey	Granite			63	67
Green	Granite			67	74
Red	Granite			74	77
Green	Granite			77	94

WATER RECORD		CASING & OPEN HOLE RECORD				SCREEN	
WATER FOUND AT - FEET: <u>75</u>	KIND OF WATER: <input checked="" type="checkbox"/> FRESH <input type="checkbox"/> SALTY <input type="checkbox"/> SULPHUR MINERALS <input type="checkbox"/> GAS	INSIDE DIA - INCHES: <u>6 1/4</u>	MATERIAL: <input checked="" type="checkbox"/> STEEL <input type="checkbox"/> GALVANIZED <input type="checkbox"/> CONCRETE <input type="checkbox"/> OPEN HOLE <input type="checkbox"/> PLASTIC	WALL THICKNESS - INCHES: <u>3/16</u>	DEPTH - FEET: FROM <u>0</u> TO <u>22</u>	SIZE of OPENING (1/2" to 12")	DIAMETER INCHES
						MATERIAL AND TYPE	LENGTH FEET
							DEPTH TO TOP OF SCREEN FEET

PLUGGING & SEALING RECORD

DEPTH SET AT - FEET: FROM 22 TO 5 MATERIAL AND TYPE: Annular Cement Grout


PUMPING TEST METHOD: PUMP BAILER

PUMPING RATE: 15 GPM DURATION OF PUMPING: 2 HOURS

STATIC LEVEL	WATER LEVEL END OF PUMPING	WATER LEVELS DURING			
<u>38</u> FEET	<u>80</u> FEET	15 MINUTES: <u>67</u> FEET	30 MINUTES: <u>74</u> FEET	45 MINUTES: <u>75</u> FEET	60 MINUTES: <u>76</u> FEET

RECOMMENDED PUMP TYPE: SHALLOW DEEP

RECOMMENDED PUMP SETTING: 92 FEET RECOMMENDED PUMPING RATE: 15 GPM



FINAL STATUS OF WELL: WATER SUPPLY OBSERVATION WELL TEST HOLE RECHARGE WELL

WATER USE: DOMESTIC STOCK IRRIGATION INDUSTRIAL OTHER

METHOD OF CONSTRUCTION: CABLE TOOL ROTARY (CONVENTIONAL) ROTARY (REVERSE) ROTARY (AIR) AIR PERCUSSION

NAME OF WELL CONTRACTOR: Jack Knox Well Drilling WELL CONTRACTOR'S LICENSE NUMBER: 2202

ADDRESS: Glenburnie, Ontario

NAME OF WELL TECHNICIAN: Arnold Munro WELL TECHNICIAN'S LICENSE NUMBER: 7008

SIGNATURE OF TECHNICIAN/CONTRACTOR: Jack Knox SUBMISSION DATE: DAY 30 MO 7 YR 90

DRILLER'S REMARKS: 80808

OFFICE USE ONLY

CONTRACTOR'S COPY

12-4-96

WATER PUMP
1045 ROUTLEDGE RD.

GOULD PUMPS, KITCHENER, ONTARIO.

SUBMERSIBLE PUMP 13 G 10422

MOTOR : FRANKLIN ELECTRIC

MODEL 2243080117

H.P. 1

AMPS 8.2

VOLTAGE 230.

PHASE 1

RPM 3450.