Ontario

The Ontario Water Resources Act

WATER WELL RECORD

1. PRINT ONLY IN SPACES PROVIDED
2. CHECK ☒ CORRECT BOX WHERE APPLICABLE

COUNTY OR DISTRICT	TOWNSHIP, BOROUGH, CITY, TOWN, VILLAGE	CON., BLOCK, TRACT, SURVEY, ETC.	LOT
FRONTENAC	KINGSTON		

OWNER (SURNAME FIRST)	ADDRESS	DATE COMPLETED
ROBINSON BOB.		DAY 19 MO. 7 YR. 74

LOG OF OVERBURDEN AND BEDROCK MATERIALS (SEE INSTRUCTIONS)

GENERAL COLOUR	MOST COMMON MATERIAL	OTHER MATERIALS	GENERAL DESCRIPTION	DEPTH - FEET FROM	DEPTH - FEET TO
BROWN	CLAY & SAND			0	20
GREY	SANDSTONE			20	90

WATER RECORD

WATER FOUND AT - FEET	KIND OF WATER
85	☐ FRESH ☐ SULPHUR ☐ SALTY ☐ MINERAL
UNTESTED	☐ FRESH ☐ SULPHUR ☐ SALTY ☐ MINERAL
	☐ FRESH ☐ SULPHUR ☐ SALTY ☐ MINERAL
	☐ FRESH ☐ SULPHUR ☐ SALTY ☐ MINERAL
	☐ FRESH ☐ SULPHUR ☐ SALTY ☐ MINERAL

CASING & OPEN HOLE RECORD

INSIDE DIAM INCHES	MATERIAL	WALL THICKNESS INCHES	DEPTH - FEET FROM	DEPTH - FEET TO
6 1/4	☒ STEEL ☐ GALVANIZED ☐ CONCRETE ☐ OPEN HOLE	188	0	25.
	☐ STEEL ☐ GALVANIZED ☐ CONCRETE ☐ OPEN HOLE			
	☐ STEEL ☐ GALVANIZED ☐ CONCRETE ☐ OPEN HOLE			

SCREEN

SIZE(S) OF OPENING (SLOT NO.)	DIAMETER INCHES	LENGTH FEET
MATERIAL AND TYPE	DEPTH TO TOP OF SCREEN FEET	

PLUGGING & SEALING RECORD

DEPTH SET AT - FEET FROM	TO	MATERIAL AND TYPE (CEMENT GROUT, LEAD PACKER, ETC.)

PUMPING TEST

PUMPING TEST METHOD	PUMPING RATE	DURATION OF PUMPING
☒ PUMP ☐ BAILER	5 GPM	1 HOURS ___ MINS

STATIC LEVEL	WATER LEVEL END OF PUMPING	WATER LEVELS DURING ☐ PUMPING ☐ RECOVERY: 15 MINUTES	30 MINUTES	45 MINUTES	60 MINUTES
12 FEET	90 FEET	FEET	FEET	FEET	90 FEET

IF FLOWING, GIVE RATE	PUMP INTAKE SET AT	WATER AT END OF TEST
GPM	FEET	☒ CLEAR ☐ CLOUDY

RECOMMENDED PUMP TYPE	RECOMMENDED PUMP SETTING	RECOMMENDED PUMPING RATE
☐ SHALLOW ☒ DEEP	85 FEET	5 GPM

LOCATION OF WELL

IN DIAGRAM BELOW SHOW DISTANCES OF WELL FROM ROAD AND LOT LINE. INDICATE NORTH BY ARROW.

DRILLERS REMARKS:

FINAL STATUS OF WELL

☒ WATER SUPPLY ☐ OBSERVATION WELL ☐ TEST HOLE ☐ RECHARGE WELL ☐ ABANDONED, INSUFFICIENT SUPPLY ☐ ABANDONED, POOR QUALITY ☐ UNFINISHED

WATER USE

☒ DOMESTIC ☐ STOCK ☐ IRRIGATION ☐ INDUSTRIAL ☐ OTHER ☐ COMMERCIAL ☐ MUNICIPAL ☐ PUBLIC SUPPLY ☐ COOLING OR AIR CONDITIONING ☐ NOT USED

METHOD OF DRILLING

☐ CABLE TOOL ☐ ROTARY (CONVENTIONAL) ☐ ROTARY (REVERSE) ☐ ROTARY (AIR) ☒ AIR PERCUSSION ☐ BORING ☐ DIAMOND ☐ JETTING ☐ DRIVING

CONTRACTOR

NAME OF WELL CONTRACTOR	LICENCE NUMBER
W H Day & Son Ltd	1704
ADDRESS: VERONA.	
NAME OF DRILLER OR BORER: GEO ALBERTSON	LICENCE NUMBER
SIGNATURE OF CONTRACTOR: W H Day	SUBMISSION DATE: DAY 19 MO. 7 YR. 74

OFFICE USE ONLY

OWNER'S COPY

FORM 7 MOE 07-091