



# The Ontario Water Resources Commission Act WATER WELL RECORD

*Big. C?*

Water management in Ontario 1. PRINT ONLY IN SPACES PROVIDED  
2. CHECK  CORRECT BOX WHERE APPLICABLE

*40' beam house*

COUNTY OR DISTRICT <i>Frontenac</i>	TOWNSHIP, BOROUGH, CITY, TOWN, VILLAGE <i>Portland</i>	CON., BLOCK, TRACT, SURVEY, ETC.	LOT
OWNER (SURNAME FIRST) <i>Larman</i>	ADDRESS <i>Don Sharbot Lake</i>	DATE COMPLETED DAY <i>21</i> MO. <i>7</i> YR. <i>71</i>	

GENERAL COLOUR	MOST COMMON MATERIAL	OTHER MATERIALS	GENERAL DESCRIPTION	DEPTH - FEET	
				FROM	TO
<i>Brown</i>	<i>Earth</i>			<i>0'</i>	<i>3'</i>
<i>Black</i>	<i>Granite</i>			<i>3'</i>	<i>180'</i>
<i>Grey</i>		<i>Granite-Limestone mixed</i>		<i>180'</i>	<i>195'</i>
<i>Black</i>	<i>Granite</i>			<i>195'</i>	<i>201'</i>

WATER RECORD	
WATER FOUND AT - FEET <i>197'</i>	KIND OF WATER <input checked="" type="checkbox"/> FRESH <input type="checkbox"/> SALTY <input type="checkbox"/> SULPHUR <input type="checkbox"/> MINERAL

CASING & OPEN HOLE RECORD			
INSIDE DIAM. INCHES <i>6 7/8</i>	MATERIAL <input checked="" type="checkbox"/> STEEL <input type="checkbox"/> GALVANIZED <input type="checkbox"/> CONCRETE <input type="checkbox"/> OPEN HOLE	WALL THICKNESS INCHES <i>3/16</i>	DEPTH - FEET FROM <i>0'</i> TO <i>10'</i> <i>10'</i> <i>201'</i>

SCREEN	SIZE(S) OF OPENING (SLOT NO.)	DIAMETER	LENGTH

PLUGGING & SEALING RECORD		
DEPTH SET AT - FEET FROM TO	MATERIAL AND TYPE (CEMENT GROUT, LEAD PACKER, ETC.)	

PUMPING TEST	PUMPING TEST METHOD		PUMPING RATE		DURATION OF PUMPING		
	<input type="checkbox"/> PUMP	<input checked="" type="checkbox"/> BAILER	<i>8</i>	GPM.	<i>2</i>	HOURS	MIN.
	STATIC LEVEL	WATER LEVEL END OF PUMPING	WATER LEVELS DURING				
	<i>60'</i>	<i>180'</i>	15 MINUTES <i>145'</i>	30 MINUTES <i>170'</i>	45 MINUTES <i>180'</i>	60 MINUTES <i>180'</i>	

LOCATION OF WELL	
IN DIAGRAM BELOW SHOW DISTANCES OF WELL FROM ROAD AND LOT LINE. INDICATE NORTH BY ARROW.	
<p><i>500.00</i></p> <p><i>ago G.L. off road 7 1/2"</i></p> <p><i>Bennett Rd.</i></p> <p><i>between Bulluck Rd. and Portland dam</i></p> <p><i>new abandoned sully.</i></p>	

FINAL STATUS OF WELL	<input checked="" type="checkbox"/> WATER SUPPLY	<input type="checkbox"/> ABANDONED, INSUFFICIENT SUPPLY
	<input type="checkbox"/> OBSERVATION WELL	<input type="checkbox"/> ABANDONED, POOR QUALITY
	<input type="checkbox"/> TEST HOLE	<input type="checkbox"/> UNFINISHED
WATER USE	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> COMMERCIAL
	<input type="checkbox"/> STOCK	<input type="checkbox"/> MUNICIPAL
	<input type="checkbox"/> IRRIGATION	<input type="checkbox"/> PUBLIC SUPPLY
METHOD OF DRILLING	<input checked="" type="checkbox"/> CABLE TOOL	<input type="checkbox"/> BORING
	<input type="checkbox"/> ROTARY (CONVENTIONAL)	<input type="checkbox"/> DIAMOND
	<input type="checkbox"/> ROTARY (REVERSE)	<input type="checkbox"/> JETTING

NAME OF WELL CONTRACTOR <i>Jack Knox</i>	LICENCE NUMBER <i>3202</i>
ADDRESS <i>Westbrook</i>	
NAME OF DRILLER OR BORER <i>Lou Doudelin</i>	LICENCE NUMBER
SIGNATURE OF CONTRACTOR <i>Jack Knox</i>	SUBMISSION DATE DAY _____ MO. _____ YR. _____

OFFICE USE ONLY	